

## **ADDENDUM NO. 1**

**July 22, 2025**

### **Controlled Demolition of 1 Price Street Nunda, NY 14517**

This addendum is hereby included in and made a part of the Contract Documents. All requirements of the original Bid Documents shall remain in force except as noted by this addendum.

The purpose of this addendum provided by LiRo Engineers, Inc. (LiRo) is to provide bidders with information on the following items:

#### **Item 1 – Responses to Questions**

Responses to questions received pertaining to this bid solicitation are provided below.

| <b><u>Question</u></b>                                      | <b><u>Response</u></b>  |
|---|---|
| 1. Can we arrange to have the house inspected for asbestos? | No, the building is condemned as structurally unsound and is not accessible for asbestos sampling. The demolition is to be conducted in accordance with 12 NYCRR 56-11.5 (NYSDOL Controlled Demolition with Asbestos in Place). |
| 2. Have you already called UDig for the property?           | Calling in Dig Safely markouts is the responsibility of the awarded contractor.   |
| 3. Are the foundations to be removed in their entirety?     | The Contractor is responsible for removal of foundations to a minimum depth of 3 feet below finished grade.   |

The Prospective Bidder shall acknowledge receipt of this addendum in their bid submittal.

**END OF ADDENDUM NO. 1**